



PDHonline Course E356 (3 PDH)

Revisions for the 2011 National Electrical Code® - Part 2

Instructor: Patrick Ouillette

2020

PDH Online | PDH Center

5272 Meadow Estates Drive
Fairfax, VA 22030-6658
Phone: 703-988-0088
www.PDHonline.com

Revisions for the 2011 NEC®, Part 2

PDH Course E356

Table of Contents

Title Page

Introduction

Chapter 2 – Wiring and Protection (cont.)

Article 250 – Grounding and Bonding

250.21(B) – Alternating-Current Systems of 50 Volts to Less Than 1000 Volts Not Required to Be Grounded – Ground Detectors.....	1
250.21(C) – Alternating-Current Systems of 50 Volts to Less Than 1000 Volts Not Required to Be Grounded – Marking	3
250.30 – Grounding Separately Derived Alternating-Current Systems	5
250.30(C) – Grounding Separately Derived Alternating-Current Systems – Outdoor Source	9
250.52(A)(2) – Grounding Electrodes – Electrodes Permitted for Grounding – Metal Frame of the Building or Structure	11
250.53(A)(2) – Grounding Electrode System Installation – Rod, Pipe, and Plate Electrodes – Supplemental Electrode Required	14
250.64(B) – Grounding Electrode Conductor Installation – Securing and Protection Against Physical Damage	16
250.64(C) – Grounding Electrode Conductor Installation – Continuous	18
250.64(D)(1) – Grounding Electrode Conductor Installation – Service with Multiple Disconnecting Means Enclosures – Common Grounding Electrode Conductor and Taps	19
250.68(C) – Grounding Electrode Conductor and Bonding Jumper Connection to Grounding Electrodes – Metallic Water Pipe and Structural Metal	20
250.121 – Use of Equipment Grounding Conductors	22
250.190 – Grounding of Systems and Circuits of Over 1 kV – Grounding of Equipment	24

250.191 – Grounding of Systems and Circuits of Over 1 kV – Grounding System at Alternating-Current Substations.....	26
--	----

Chapter 3 – Wiring Methods and Materials

Article 300 – Wiring Methods

300.4(E) – Protection against Physical Damage – Cables, Raceways, or Boxes Installed in or Under Roof Decking	27
300.4(H) – Protection against Physical Damage – Structural Joints	29
300.5(C) – Underground Installations – Underground Cables Under Buildings	30
300.11(A)(2) – Securing and Supporting – Secured in Place – Non-Fire-Rated Assemblies	31
300.22 – Wiring in Ducts Not Used for Air Handling, Fabricated Ducts for Environmental Air, and Other Spaces for Environmental Air (Plenums)	33

Article 310 – Conductors for General Wiring

Article 310, Tables.....	35
310.15(B) – Ampacities for Conductors Rated 0-2000 Volts – Tables	36
Table 310.15(B)(16) – Ampacities for Conductors Rated 0-2000 Volts – Tables	37

Article 314 – Outlet, Device, Pull, and Junction Boxes; Conduit Bodies; Fittings; and Handhole

Enclosures

314.27(C) – Outlet Boxes – Boxes at Ceiling-Suspended (Paddle) Fan Outlets	39
314.28(E) – Pull and Junction Boxes and Conduit Bodies – Power Distribution Blocks.....	41